

## EU DECLARATION OF CONFORMITY

We the manufacturer: **PMV Automation AB , Korta gatan 9, SE-171 54 Solna**  
under sole responsibility declare that the product,

### Digital Valve Positioner (D3)

is in conformity with the following harmonised legislation:

Directive: **2014/30/EU (EMC)**

Applied Standards: **EN 61000-6-2 , 3 and 4**

Directive: **2014/35/EU (Certain voltage limits)**

Applied Standards: **EN 60204-1, IEC 61010-1**

Directive: **2014/34/EU (ATEX)**

Applied Standards Ex ia : **EN 60079-0:2009 (EN 60079-0:2012 +A11:2013)\***

**EN 60079-11:2007 (EN 60079-11:2012)\***

**EN 60079-26:2007 (EN 60079-26:2015)\***

Applied Standards Ex db/tb: **EN 60079-0:2012 +A11:2013)**

**EN 60079-1:2014**

**EN 60079-31:2014**

*\* A review between standards used during certification and the harmonized standards (in parenthesis) have identified no significant change relevant for the construction and commissioning of this product.*

Quality Assurance:

**Nemko , P.O.Box 73 Blindern, N-0314 Oslo, Norway**

Notified body Certificate Ex ia:

**Nemko , P.O.Box 73 Blindern, N-0314 Oslo, Norway**

Notified body Certificate Ex db/tb :

**DNV GLN Nemko Presafe As, Veritasveien 3, 1363 Høvik**

**Norway**

Product marking :

EU-type examination  
Certificate

Model code (x=any character)



II 1G Ex ia IIC T4 Ga Ta:80°C

II 1G Ex ia IIC T4 Ga Ta:80°C FISCO Field Device

**Nemko 03ATEX110X**

**D3lxx-xxxxxx-xxxx**

**D3Yxx-xxxxxx-xxxx**



II 2G Ex db IIB+H2 T6 -20°C ≤ Ta ≤ +60°C.

II 2D Ex tb IIIC T100°C -20°C ≤ Ta ≤ +80°C


**Presafe 17 ATEX 11598X**

**D3Exx-xxxxxx-xxxx**

**D3Fxx-xxxxxx-xxxx**

Authorized Person for the manufacturer

PMV Automation AB  
Korta Gatan 9  
SE-171 54 Solna  
Sweden

  
Åke Jonasson  
Quality Manager  
Solna, Sweden

Issued: 2004-06-17  
Updated: 2019-05-22