



Certificate of conformity

A21/000140

In compliance with 2014/68/EU Directive, relating to pressure equipment, the notified body AENOR (n. 0099) certifies that

INTERAPP VALCOM, S.A.

registered office A 1 28770 SAN AGUSTÍN DEL GUADALIX (Madrid - España)

applies a **Full quality assurance system in accordance with Module H**

of directive 2014/68/UE

References Specified in Annex to the Certificate

Production site A 1 28770 SAN AGUSTÍN DEL GUADALIX (Madrid - España)

Certification scheme In order to grant this certificate, AENOR has assessed the quality system operated by the manufacturer in order to determine whether the quality system satisfies the requirements referred to in Directive 2014/68/EU. AENOR carries out surveillance audits to make sure that the manufacturer maintains and applies the quality system.

First issued on 2024-04-25
Validity 2027-04-25

Rafael GARCÍA MEIRO
CEO



Certificate of conformity

A21/000140

Annex to Certificate

SCOPE

Industrial valves. Metallic butterfly valves model DESPONIA, DESPONIA PLUS, AQUARIA PLUS, S820 (see details in the annex to the certificate)

Models	Characteristics (*)	Category PED	Standard/Code of design
Aquaria Plus S820	DN 25/32 to DN 1600 PN 2,5/10/16/20 TS: -10 to 130 °C Fluid PED: group 1 and 2	II	EN 593:2017; AD-2000
Desponia	DN 25/32 to DN 1600 PN 2,5/10/16/20 TS: -10 to 200 °C Fluid PED: group 1 and 2	II	EN 593:2017; AD-2000
Aquaria Plus S820	DN 350 a DN 1200 PN 10/16 TS: -10 to 130 °C Fluid PED: group 1	III	EN 593:2017
Desponia	DN 350 to DN 1200 PN 10/16 TS: -10 to 200 °C Fluid PED: group 1	III	EN 593:2017
Desponia Plus	DN 25/32 to DN 600 PN 2,5/10/16/20 TS: -40 to 200 °C Fluid PED: group 1 and 2	II	EN 593:2017; AD-2000
Desponia Plus	DN 350 to DN 600 PN 10/16 TS: -40 to 200 °C Fluid PED: group 1	III	EN 593:2017

First issued on 2024-04-25
Validity 2027-04-25

