

Approval Number: 1911558
Test Report: MA6655/B & MA6979/O



25th August 2020

Intermarp (Italia) Spa
Via Matteotti 42/46,
1-28060 Granozzo (Novara),
Italy

Water Regulations Advisory Scheme Ltd.
Unit 13,
Willow Road,
Pen y Fan Industrial Estate,
Crumlin,
Gwent,
NP11 4EG

WATER REGULATIONS ADVISORY SCHEME LTD. (WRAS)
MATERIAL APPROVAL

The material referred to in this letter is suitable for contact with wholesome water for domestic purposes having met the requirements of BS6920-1:2000 and/or 2014 'Suitability of non-metallic products for use in contact with water intended for human consumption with regard to their effect on the quality of the water'.

The reference relates solely to its effect on the quality of the water with which it may come into contact and does not signify the approval of its mechanical or physical properties for any use.

RUBBERS - ETHYLENE PROPYLENE DIENE MONOMER (EPDM) - MATERIAL ONLY.

5365

'APE 70 N'. Black coloured, injection moulded EPDM material. Shore hardness 70. Tested in-radius size 1.05mm. For use with water up to 60°C.

APPROVAL NUMBER: 1911558

APPROVAL HOLDER: INTERMARP (ITALIA) SPA

The Scheme reserves the right to review approval.

Approval 1911558 is valid between November 2019 and November 2024

An entry, as above, will accordingly be included in the Water Fittings Directory on-line under the section headed, "Materials which have passed full tests of effect on water quality".

The Directory may be found at: www.wras.co.uk/directory

Yours faithfully

A handwritten signature in black ink, appearing to read 'Jason Furnival', written in a cursive style.

Jason Furnival
Approvals & Enquiries Manager
Water Regulations Advisory Scheme