

Approval Number 2111525
Test Report: MA7395/P/1



24th November 2021

Compounds AG
Barzloostrasse 1
8330 Pfaffiken ZH
Switzerland

Water Regulations Approval Scheme Ltd.
Unit 13,
Willow Road,
Pen y Fan Industrial Estate,
Crumlin,
Gwent,
NP11 4EG

**WATER REGULATIONS APPROVAL SCHEME LTD. (WRAS)
MATERIAL APPROVAL**

The material referred to in this letter is suitable for contact with wholesome water for domestic purposes having met the requirements of BS6920-1:2000 and/or 2014 'Suitability of non-metallic products for use in contact with water intended for human consumption with regard to their effect on the quality of the water'.

The reference relates solely to its effect on the quality of the water with which it may come into contact and does not signify the approval of its mechanical or physical properties for any use.

RUBBERS- ETHYLENE PROPYLENE DIENE MONOMER (EPDM) - MATERIAL ONLY.

5365

'Sunaflex T 8157'. Black coloured, compression moulded EPDM rubber material. Shore hardness 60. Tested in-radius size 1.0mm. For use with water up to 23°C.

APPROVAL NUMBER: 2111525
APPROVAL HOLDER: COMPOUNDS AG

This is a re-approval of 1610511 which is valid between October 2016 and October 2021.

The Scheme reserves the right to review approval.
Approval 2111525 is valid between November 2021 and November 2026

An entry, as above, will accordingly be included in the Water Fittings Directory on-line under the section headed, "Materials which have passed full tests of effect on water quality".

The Directory may be found at: www.wrasapprovals.co.uk/approvals-directory/

Yours Faithfully

Ian Hughes
WRAS Approvals Manager

30.11.2021

Compounds AG
Barzloostrasse 1
CH-8330 Pfäffikon ZH